

**Top Ten Deficiencies National and Virginia
Life Safety Code
Long Term Care**

RANK	NATIONAL 2008	VIRGINIA 2008	VIRGINIA 2007	VIRGINIA 2006
#1	K0018. Corridor doors	K0147. Electrical wiring and equipment	K0018. Corridor doors	K0147. Electrical wiring and equipment
#2	K0029. Hazardous areas - separation	K0018. Corridor doors	K0147. Electrical wiring and equipment	K0018. Corridor doors
#3	K0062. Sprinkler system maintenance	K0062. Sprinkler system maintenance	K0056. Automatic Sprinkler system	K0029. Hazardous areas - separation
#4	K0147. Electrical wiring and equipment	K0029. Hazardous areas - separation	K0029. Hazardous areas - separation	K0056. Automatic Sprinkler system
#5	K0038. Exit Access	K0025. Smoke partition construction	K0062. Sprinkler system maintenance	K0025. Smoke partition construction
#6	K0025. Smoke partition construction	K0038. Exit Access	K0025. Smoke partition construction	K0038. Exit Access
#7	K0050. Fire drills	K0056. Automatic Sprinkler system	K0027. Doors in smoke partitions.	K0062. Sprinkler system maintenance
#8	K0056. Automatic Sprinkler system	K0052. Testing of the fire alarm	K0038. Exit Access	K0069. Cooking equipment
#9	K0144. Generator inspected/tested	K0027. Doors in smoke partitions.	K0017. Corridor walls	K0027. Doors in smoke partitions.
#10	K0052. Testing of the fire alarm.	K0069. Cooking equipment	K0130. Other	K072 Furnishing and decorations

3/12/2009